



**City of Santa Clara
Building Inspection Division**

1500 Warburton Avenue
Santa Clara, CA 95050
Phone: (408) 615-2440
Fax: (408) 241-3823
<http://www.ci.santa-clara.ca.us>

WATER HAMMER ARRESTERS

October 15, 2004

City of Santa Clara Building Inspection Division 1500 Warburton Avenue Santa Clara, CA 95050	Inspection Division: (408) 615-2440 Permit Center: (408) 615-2420 Automated Inspection System: (408) 615-2400 Fax: (408) 241-3823
WATER HAMMER ARRESTERS	

Water hammer arresters (Complying With ASSE 1010) are required where quick-closing valves are installed. Access to all arrestors is required for repair or replacement. Air chambers made from pipe and a hard cap can not be accepted.

Examples Of Quick-Closing Valves

Drinking Fountains

Dishwashers

Solenoid -Actuated

Self-Closing

Spring-Loaded

Washing Machines

Touchless Faucets

Ice Makers

Any Valve That Will Go From Full Flow To No Flow In Normal Use

Flushometers, Metering Faucets And Float Valves Are Not Normally Designed To Be Quick- Closing. Check with the manufacturer.

Access panels are required.

Some CPVC installations may not require water hammer arrestors. Check the manufacturers installation instructions.